INSPECTION REPORT

PERMIT NUMBER:		BP-15-00218	OWNER'S NAME:	SCHMIT	
DATE:		5/29/2015	TYPE:	Final	
TIME STARTED:		11:13 AM	INSPECTOR:	Justin Bennett	
MAP NUMBER:		17-18-08058-0004			
	1. Provide (2	Provide (2) bolts @ rafter to post connection per detail 1/S3 or engineers approval (cl			
	ouded)				
	2. Provide (2) SDS screws @ gable ends per detail 4/S3 (clouded)				
	3. Provide framing per detail 3/S4 @ east wall center window				
	4. Trusses Ok				
INSTRUCTIONS: Make corrections above/Re-inspection					
mane concedient above to inoposition					
NEXT INSPECTION: Re-inspection					
RE-INSPECTION FEE DUE? VES \$					
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION					
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:					
	iustin_bennett @co.kittitas.wa.us				
 INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 Main Office Line: 509-962-7506 					