



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00226

OWNER'S NAME: DOERRFELD

DATE: 10/26/2015

TYPE: Final

TIME STARTED: 12:48 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 20-14-12051-0606

	1. Floor/Attic Insulation OK.
	2. Decks Not Permitted. Maybe Permitted on Another Permit #. Unable to Verify or Inspect Without Drawings.
	3. Deck at Backdoor Required Gaurdail and Handrail. See Stair/Guardrail/Handrail Requirements in IRC. Handout Available by Request.
	4. Septic/Access OK.
	5. Unable to Verify Hot Water for Plumbing Final.
	6. Unable to Verify Woodstove For Final. Installation Manual Needed.

INSTRUCTIONS: Make Corrections Above. Contact Inspector with Questions.

NEXT INSPECTION: ReInspect.

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

jeremv.haberman @co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506