## **INSPECTION REPORT**

PERMIT NUMBER:	BP-15-00227	OWNER'S NAME:	WEEKES	
DATE:	6/17/2016	TYPE:	Rough-in plumbing	
TIME STARTED:	11:13 AM	INSPECTOR:	Amber Green	
MAP NUMBER:	18-19-24054-0002			
1. Framing (	OK			
2. Exhaust OK				
3. Drain/Waste/Vent needs to be on test for inspection.				
4. Supply lines can be working pressure/live.				
INSTRUCTIONS: Cap and fill DWV with water with at least 10' of head. Or fill with air and guage with a				
mi	nimum of 5lbs.			
NEXT INSPECTION: Re-Plumbing				
RE-INSPECTION FEE I	OUE? NO YES		\$	
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION				
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:				
	@co.kittitas.wa.us			
<ul> <li>INSPECTION REQUEST LINE: <a href="www.co.kittitas.wa.us/cds/request.asp">www.co.kittitas.wa.us/cds/request.asp</a> or 509-962-7694 ◆</li> <li>411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 ◆ Main Office Line: 509-962-7506</li> </ul>				