INSPECTION REPORT

PERMIT NUMBER: BP-15-00243 OWNER'S NAME: CHERNYAK

DATE:	12/3/2015	TYPE:	Slab plumbing
TIME STARTE	D: 12:24 PM	INSPECTOR:	Jessica Contratto
MAP NUMBE	r: 22-11-09054-0033		
1. DWV at 15#-ok			
INSTRUCTIONS: ok to cover			
NEXT INSPECTION: Shearwalls			
RE-INSPECTION FEE DUE? VES \$			
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION			
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:			
iessica.contratto @co.kittitas.wa.us			
• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 • 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506			