



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00247

OWNER'S NAME: READ

DATE: 4/13/2016

TYPE: Final

TIME STARTED: 12:13 PM

INSPECTOR: Justin Bennett

MAP NUMBER: 19-16-17050-0027

1. Breezeway covered - Noted @ insulation not to cover
2. Revisions need to be inspected prior to cover
3. Remove portion of breezeway cover for inspection
4. Verify attic insulation @ re-inspection

INSTRUCTIONS: Remove ceiling/Re-Inspection

NEXT INSPECTION: Re-Inspection

RE-INSPECTION FEE DUE? NO YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: justin.bennett @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506