



KITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00269

OWNER'S NAME: DAVIS

DATE: 12/10/2015

TYPE: Final

TIME STARTED: 3:00 PM

INSPECTOR: Jessica Contratto

MAP NUMBER: 17-18-23020-0017

1. Landings at exterior doors
2. Stair requires handrail, and guards to have no more than 4"space between
3. Fireplace needs permitting and inspection
4. Room added above garage area. Added post in garage for support. Ledgered off wall for framing. Windows added with minimal heating by wall heater.
5. Trusses require 10' O.C. bottom chord bracing in lieu of rigid ceiling
6. L&I inspection verification needed prior to final

INSTRUCTIONS: Submit revision for added room over garage and state use of room to determine if fire separation is necessary. Obtain permit for added woodstove

NEXT INSPECTION: Re-inspect

RE-INSPECTION FEE DUE? NO YES \$ _____
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ jessica.contratto@co.kittitas.wa.us

• **INSPECTION REQUEST LINE:** www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506