



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00269

OWNER'S NAME: DAVIS

DATE: 7/12/2016

TYPE: Final

TIME STARTED: 9:33 AM

INSPECTOR: Jessica Contratto

MAP NUMBER: 17-18-23020-0017

1. Fireplace included on revision-Install ok
2. Truss bracing ok
3. Landings ok
4. Loft framing ok
5. Guard on stairs does not meet code requirements. 4" max. opening size.
Additional 2x4's ?
6. Cannot locate L&I approval for final

INSTRUCTIONS: Confirm L&I, complete guard at stairs

NEXT INSPECTION: re-inspect

RE-INSPECTION FEE DUE? NO YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: _____ [jessica.contratto @co.kittitas.wa.us](mailto:jessica.contratto@co.kittitas.wa.us)

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506