



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-15-00276

OWNER'S NAME: GRISWOLD

DATE: 8/6/2015

TYPE: Shearwalls

TIME STARTED: 12:30 PM

INSPECTOR: Justin Bennett

MAP NUMBER: 19-16-06050-0007

	1. Tighten up panel edge nailing @ south wall (clouded on dwgs)
	2. Install studs and portal framing (clouded on dwgs)
	3. Straps Ok
	4. Anchor bolts Ok

**INSTRUCTIONS:** Complete panel nailing/Ok to cover exterior once complete/Verify portal framing @ Framing

**NEXT INSPECTION:** Plumb/Mech

RE-INSPECTION FEE DUE?



NO



YES

\$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

justin.bennett @co.kittitas.wa.us

• **INSPECTION REQUEST LINE:** [www.co.kittitas.wa.us/cds/request.asp](http://www.co.kittitas.wa.us/cds/request.asp) or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506