INSPECTION REPORT

PERMIT NUMBER: BP-15-00288 OWNER'S NAME: JONES

DATE:		9/15/2015	TYPE:	Rough-in plumbing	
TIME STA	ARTED:	10:20 AM	INSPECTOR:	Lou Whitford	
MAP NUMBER:		17-18-07060-0014			
1.	1. OK WATER SUPPLY 78#'S/20 MINUTES				
2.	2. OK DWV STACK TEST/ 20 MINUTES				
INSTRUCTIONS:					
NEXT INSPECTION: MECHANICAL/ FRAMING					
RE-INSPECTION FEE DUE? VES \$					
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION					
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:					
	lou.whitford @co.kittitas.wa.us				
• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •					
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506					