



KITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

# INSPECTION REPORT

PERMIT NUMBER: BP-15-00288                      OWNER'S NAME: JONES  
 DATE: 1/21/2016                                      TYPE: Final  
 TIME STARTED: 10:57 AM                          INSPECTOR: Jessica Contratto  
 MAP NUMBER: 17-18-07060-0014

1. Seal penetrations in mechanical alcove
2. Water shut off must have fire-rated cover or sheetrock. Cannot be open to garage side.
3. Door from garage to residence must be self closing
4. No crawlspace venting installed
5. Fresh air damper to furnace not hooked up. Seal intake at return where connecting
6. Finish drywall on furnace side of mechanical alcove
7. Blower door test ok
8. Sewer and access approved
9. Fire sprinkler approved

**INSTRUCTIONS:** Complete above corrections

**NEXT INSPECTION:** re-inspect

RE-INSPECTION FEE DUE?     NO     YES    \$ \_\_\_\_\_  
**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

\_\_\_\_\_ [jessica.contratto@co.kittitas.wa.us](mailto:jessica.contratto@co.kittitas.wa.us)

• **INSPECTION REQUEST LINE:** [www.co.kittitas.wa.us/cds/request.asp](http://www.co.kittitas.wa.us/cds/request.asp) or 509-962-7694 •  
 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506