



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00326

OWNER'S NAME: FAIRLAMB

DATE: 9/15/2015

TYPE: Exterior shear

TIME STARTED: 2:49 PM

INSPECTOR: Jessica Contratto

MAP NUMBER: 20-15-19050-0014

	1. interior shear ok
	2. tighten up nailing at front garage return walls to 3"
	3. add bottom plate nailing at P1-4 walls

INSTRUCTIONS: complete above, ok to cover

NEXT INSPECTION: plumb/mech

RE-INSPECTION FEE DUE? NO YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ jessica.contratto@co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •
 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506