



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00326 OWNER'S NAME: FAIRLAMB
DATE: 11/5/2015 TYPE: Rough-in plumbing
TIME STARTED: 4:43 PM INSPECTOR: Jeremy Haberman
MAP NUMBER: 20-15-19050-0014

	1. Plumbing OK.
	2. DWV on Stack Test. OK.
	3. Supply Live. OK.
	4. NOTE: Mechanical Rough In Inspection Also Requested.
	5. Supply Ductwork in Crawl Not Insulated.
	6. Range Vent Duct in Attic Not Insulated.

INSTRUCTIONS: Make Corrections Above. OK to Call for Framing.

NEXT INSPECTION: Framing

RE-INSPECTION FEE DUE? NO YES \$ _____
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ jeremy.haberman@co.kittitas.wa.us

• **INSPECTION REQUEST LINE:** www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506