



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00326

OWNER'S NAME: FAIRLAMB

DATE: 11/16/2015

TYPE: Framing and mechanical

TIME STARTED: 12:25 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 20-15-19050-0014

	1. Mechanical OK. Duct Insulation to be Verified at Insulation.
	2. Fireplace Rough In/Draftstop OK.
	3. Trusses OK.
	4. Chimney Box On RNailing/Holdowns Not Verified? Not Present? Provide Engineers OK.

INSTRUCTIONS: OK to Insulate.

NEXT INSPECTION: Insulation

RE-INSPECTION FEE DUE? NO YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ jeremy.haberman@co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •
 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506