INSPECTION REPORT

OWNER'S NAME: BAYLES

TYPE: Post holes

PERMIT NUMBER: BP-15-00361

DATE:

7/17/2015

TIME STARTE	o: 1:50 PM	INSPECTOR:	Justin Bennett
MAP NUMBEI	R: 19-19-32010-0003		
1. Setbacks Ok			
2. Post holes Ok			
3. Maintain 6" punch pad below posts when pouring			
4. Ok to pour			
INSTRUCTIONS: Maintain 6" punch pad/Hold PT post up 6" prior to pour/Ok to pour			
NEXT INSPECTION: Framing			
RE-INSPECTION FEE DUE? VES \$			
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION			
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:			
iustin_bennett @co.kittitas.wa.us			
• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 • 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506			
, , , , , , , , , , , , , , , , , , , ,			