



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00364

OWNER'S NAME: REIMER

DATE: 9/9/2015

TYPE: Exterior shear

TIME STARTED: 11:42 AM

INSPECTOR: Jessica Contratto

MAP NUMBER: 20-15-19051-0055

1. exterior shear ok
2. interior hold downs ok
3. re-nail sill plate with galvanized nails
4. engineer approval for straps at garage return walls in lieu of HD
5. interior shear ok one side. Check other side before drywall cover

INSTRUCTIONS: ok to cover exterior after galv. nails in entire sill plate

NEXT INSPECTION: plumb/mech

RE-INSPECTION FEE DUE? NO YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ jessica.contratto@co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506