



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-15-00371

OWNER'S NAME: HART

DATE: 5/24/2016

TYPE: Final

TIME STARTED: 2:01 PM

INSPECTOR: Justin Bennett

MAP NUMBER: 20-15-22000-0011

1. Complete weather tight membrane @ exterior (scratch coat is acceptable)
2. Seal exterior penetrations @ refrigerant lines on west side of house
3. Seal exterior penetration @ condensate on west side of house
4. Maintain fire separation @ garage (next to electrical panel)
5. Install straps on water heater
6. Install fire rated door @ garage
7. Verify Septic Final
8. Verify Fire Final
9. Blower door Ok
10. Insulation Ok
11. FLS Ok

INSTRUCTIONS: Make above corrections/Re Inspection

NEXT INSPECTION: Re-Inspection

RE-INSPECTION FEE DUE?



NO



YES

\$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  
ADDRESS: justin.bennett @co.kittitas.wa.us

**INSPECTION REQUEST LINE: 509-962-7694**

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506