



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00377 OWNER'S NAME: FARMER BROWN LLC
DATE: 10/21/2015 TYPE: Final
TIME STARTED: 9:46 AM INSPECTOR: Jeremy Haberman
MAP NUMBER: 18-20-19040-0010

	1. Trusses OK.
	2. Framing OK.
	3. Stairs/Railings OK.
	4. L&I Inspection Required for Final.
	5. Fall Protection Required from Loft. Railing with 4" Minimum Pass Thru or Drywall Required.
	6. NOTE: Called contact "Jeff" with Steel Structures. Attempted to leave message. Mailbox was full.
	7. Stair Landing Must be 36" Unobstructed at Top of Lower Flight.

INSTRUCTIONS: Make Correction Above. Call for ReInspect.

NEXT INSPECTION: Final

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ jeremy.haberman @co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506