INSPECTION REPORT

INST ECTION KET OKT			
PERMIT NUMBER:	BP-15-00391	OWNER'S NAME:	TUMBLE CREEK GOLF
DATE:	2/24/2016	TYPE:	Shearwalls
TIME STARTED:	12:26 PM	INSPECTOR:	Jessica Contratto
MAP NUMBER:	20-14-24050-0005		
1. Exterior shear ok 2. A35 clips to blocking ok 3. Straps to garage door headers ok on exterior 4. Provide updated floor plan for building being shortened from original plan (received 2-29-16) INSTRUCTIONS: Provide new floor plan, ok to cover exterior NEXT INSPECTION: Framing			
RE-INSPECTION FEE			\$
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION			
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL			

INSPECTION REQUEST LINE: 509-962-7694

ADDRESS:

http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506

iessica.contratto @co.kittitas.wa.us