



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-15-00391

OWNER'S NAME: TUMBLE CREEK GOLF

DATE: 4/6/2016

TYPE: Final

TIME STARTED: 1:12 PM

INSPECTOR: Jessica Contratto

MAP NUMBER: 20-14-24050-0005

1. Truss Bracing on A03, A05
2. Trusses designed for rigid ceiling applied to bottom chord. Provide updated engineering for omittance of ceiling and any added bracing requirements
3. Dormers not built per 4/S3.1 Provide engineer approval for as-built condition
4. Fire marshal final needed for commercial building
5. Smoke detectors not installed?
6. Post down below girder trusses on ends of building
7. Provide landing at man door
8. L&I final needed on electriccal for commercial building

INSTRUCTIONS: Complete above, call for re-inspection

NEXT INSPECTION: re-inspect

RE-INSPECTION FEE DUE?  NO  YES \$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  
ADDRESS: \_\_\_\_\_ [jessica.contratto @co.kittitas.wa.us](mailto:jessica.contratto@co.kittitas.wa.us)

**INSPECTION REQUEST LINE: 509-962-7694**

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506