INSPECTION REPORT

OWNER'S NAME: FORTUNE CREEK LLC

TYPE: Exterior shear

PERMIT NUMBER: BP-15-00393

DATE:

9/24/2015

TIME STARTED:		10:11 AM	INSPECTOR:	Jessica Contratto
MAP NUMBER:		19-15-07061-0030		
	1. exterior nailing/straps ok			
	2. nuts to be tightened an hold downs			
	3. Hold down in basement bath not connected to 2 full height studs			
	4. strap trimmers over header to top plate for continuos path at garage door hold downs st			
	uds			
INSTRUCTIONS: see corrections at next inspection, ok to cover exterior				
NEXT INSPECTION: plumb/mech				
RE-INSPECTION FEE DUE? VES \$				
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION				
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:				
iessica.contratto @co.kittitas.wa.us				
• INSPECTION REQUEST LINE: <u>www.co.kittitas.wa.us/cds/request.asp</u> or 509-962-7694 •				
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506				