



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00393

OWNER'S NAME: FORTUNE CREEK LLC

DATE: 10/20/2015

TYPE: Rough-in plumbing

TIME STARTED: 9:21 AM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 19-15-07061-0030

	1. Plumbing Rough In OK.
	2. DWV on Stack Test. Supply Live.
	3. Gas LineOK. Pressure at 15#/15min.
	4. Mechanical OK.
	5. REMINDER: Shear Corrections Still Outstanding. Holdown in Basement Bath Does Not Coni
	to (2) Full Height Studs.

INSTRUCTIONS: OK to Call for Framing Once Corrections are Made.

NEXT INSPECTION: Framing.

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ jeremy.haberman @co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506