



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00399

OWNER'S NAME: THE PASS LLC

DATE: 7/1/2016

TYPE: Slab plumbing

TIME STARTED: 2:24 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 22-11-04055-0016

1. DWV on Stack OK.

INSTRUCTIONS: OK to BACKfill

NEXT INSPECTION: Radiant

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: _____ [jeremy.haberman @co.kittitas.wa.us](mailto:jeremy.haberman@co.kittitas.wa.us)

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506