



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-15-00399

OWNER'S NAME: THE PASS LLC

DATE: 10/12/2016

TYPE: Mechanical and plumbir

TIME STARTED: 3:28 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 22-11-04055-0016

1. NOTE: Prior Corrections Not Addressed Per Contractors Request. Contractor Request Plumbing Rough In Inspection Only.
2. Gas Line OK. Gas Line at 30#/15min. OK.
3. Plumbing Rough In OK. DWV on Stack Test. Supply at 80#/15min. OK.

### INSTRUCTIONS:

NEXT INSPECTION: Shear or Mechanical

RE-INSPECTION FEE DUE?



NO



YES

\$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  
ADDRESS: \_\_\_\_\_ [jeremy.haberman@co.kittitas.wa.us](mailto:jeremy.haberman@co.kittitas.wa.us)

**INSPECTION REQUEST LINE: 509-962-7694**

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506