KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00488

OWNER'S NAME: HOWARD

DATE: 5/19/2016

TYPE: Mechanical and plumbir

TIME STARTED: 11:01 AM

INSPECTOR: Justin Bennett

MAP NUMBER: 20-14-17050-0411

1. DWV @ 0# - Needs to be 5#/15 mins
2. Vent disconnected in East Bedroom
3. L&I inspection not complete @ time of inspection
4. Supply @ 95#/15 mins - Ok
5. Exhaust Ok

INSTRUCTIONS: Complete corrections above/Call for L&I Inspection

NEXT INSPECTION: Framing

RE-INSPECTION FEE DUE? ☑ **NO** ☐ **YES** **$ _____**

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:_____justin.bennett **@co.kittitas.wa.us**

INSPECTION REQUEST LINE: 509-962-7694

http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506