KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER:	BP-15-00490	**OWNER'S NAME:**	BOUILLON
DATE:	10/27/2015	**TYPE:**	Shearwalls
TIME STARTED:	1:29 PM	**INSPECTOR:**	Jeremy Haberman
MAP NUMBER:	18-19-32063-0003		

	1. Exterior Shear OK.
	2. Interior Shear Not Seen. "H" Interior Walls Must be Sheeted With Plywood Unless Otherwi
	se Approved by Engineer.

INSTRUCTIONS: OK to Cover Exterior

NEXT INSPECTION: Final

RE-INSPECTION FEE DUE? ☑ **NO** ☐ **YES** **$** _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____jeremy.haberman **@co.kittitas.wa.us**