KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER:	BP-15-00510	**OWNER'S NAME:**	CASCADE VIEW INC
DATE:	9/21/2015	**TYPE:**	Framing
TIME STARTED:	9:59 AM	**INSPECTOR:**	Jeremy Haberman
MAP NUMBER:	18-18-27071-0131		

	1. Fill Void in Top Plate at Upstairs Girder Bearing. Strap Across Top Plate Break at Same
	Point.
	2. Infill Studs Under Beam Bearing Point in Corner of Garage.
	3. Window in Garage Annex/Pantry Wall on Main Floor Not Per Plan. Window Opening Compr
	es Shear Wall. Trimmer Under Header Does Not Fully Contact Bottom PlateTrimmer and King
	structed by DWV.
	4. NOTE: Window IN Shear/Header Support Photo Saved in 'T' Drive.
	5. 4x4 Support Post at Porh Not Installed, Footing Not Poured. Pier Footing Size Verified.
	OK to Pour.

INSTRUCTIONS: Make Corrections Above. Obtain Engineers Approval for Shearwall/Window/Framing Correction. OK to Insulate.

NEXT INSPECTION: Insulation.

RE-INSPECTION FEE DUE? ☑ **NO** ☐ **YES** **$** _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

jeremy.haberman **@co.kittitas.wa.us**