KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00675

OWNER'S NAME: BRADLEY

DATE: 10/13/2016

TYPE: Mechanical and plumbir

TIME STARTED: 1:08 PM

INSPECTOR: Justin Bennett

MAP NUMBER: 17-17-03000-0005

1. DWV @ 5#/15 mins - Ok
2. Supply @ 62#/15 mins - Ok
3. Plumbing RI Ok
4. Exhaust Ok
5. HVAC Supply and OA not complete

INSTRUCTIONS: Complete HVAC Installation

NEXT INSPECTION: Framing

RE-INSPECTION FEE DUE? ☑ **NO** ☐ **YES** **$ _____**

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:_____justin.bennett **@co.kittitas.wa.us**

INSPECTION REQUEST LINE: 509-962-7694

http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506