KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER:	BP-15-00682	**OWNER'S NAME:**	CASCADE VIEW
DATE:	10/16/2015	**TYPE:**	Slab plumbing
TIME STARTED:	12:37 PM	**INSPECTOR:**	Jeremy Haberman
MAP NUMBER:	18-18-27071-0152		

	1. Slab Plumbing OK. 6#/15min. OK.
	2. Pier Footings Not Seen.

INSTRUCTIONS: OK to Backfill

NEXT INSPECTION: Thickened Footings/Slab Insulation

RE-INSPECTION FEE DUE? ☐ **NO** ☐ **YES** **$** _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____jeremy.haberman **@co.kittitas.wa.us**