KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00712

OWNER'S NAME: HARRIS

DATE: 6/7/2016

TYPE: Insulation

TIME STARTED: 10:21 AM

INSPECTOR: Justin Bennett

MAP NUMBER: 20-14-24051-0710

1. Corrections 1 & 3 Ok
2. Correction 2 - P trap not complete
3. Correction 4 - Make up air not complete
4. Correction 5 - Truss bracing not complete
5. Correction 6 - Sheetrock @ Furnace not complete
6. Range Hood Exhaust not complete
7. Crawl Access Ok
8. DO NOT COVER
9. Wall Insulation Ok
10. Rafter Insulation Ok

INSTRUCTIONS: DO NOT COVER/Complete ALL above corrections/Re-Inspection

NEXT INSPECTION: Re-Inspection

RE-INSPECTION FEE DUE? ☑ **NO** ☐ **YES** **$ _____**

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS: justin.bennett **@co.kittitas.wa.us**

INSPECTION REQUEST LINE: 509-962-7694

http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506