KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00729 **OWNER'S NAME:** GEISE

DATE: 3/25/2016 **TYPE:** Slab plumbing

TIME STARTED: 11:24 AM **INSPECTOR:** Amber Green

MAP NUMBER: 17-18-08000-0057

	1. H2O (95#/15mins) - OK
	2. DWV must be at a minimum of 5 pounds for inspection.

INSTRUCTIONS: Check for leaks. Re-test. Re-Call Inspection.

NEXT INSPECTION: Slab Plumbing

RE-INSPECTION FEE DUE? ☑ **NO** ☐ **YES** **$** _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____amber.green **@co.kittitas.wa.us**