KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER:	BP-15-00782	**OWNER'S NAME:**	DAZEY
DATE:	7/1/2016	**TYPE:**	Foundation walls
TIME STARTED:	11:11 AM	**INSPECTOR:**	Justin Bennett
MAP NUMBER:	18-20-03000-0008		

1. Foundation Walls have (#4) 12" OC both vertical and horizontal
2. Interior pads Ok
3. NOTE: Revision forth coming for 10' high foundation walls
4. Pour at your own risk until revision can be confirmed

INSTRUCTIONS: Pour @ contractor risk pending revised engineering for wall height

NEXT INSPECTION: Slab Insulation

RE-INSPECTION FEE DUE? ☑ **NO** ☐ **YES** **$** _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS: justin.bennett **@co.kittitas.wa.us**

INSPECTION REQUEST LINE: 509-962-7694

http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506