KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER:	BP-15-00812	**OWNER'S NAME:**	BALES
DATE:	8/17/2016	**TYPE:**	Insulation
TIME STARTED:	1:02 PM	**INSPECTOR:**	Justin Bennett
MAP NUMBER:	20-14-24051-0630		

1. Provide vapor barrier @ 2nd Flr shower on south side (no foam)
2. Complete garage and trash room insulation
3. Confirm tenting inspection is complete

INSTRUCTIONS: Complete above/Re-Inspection

NEXT INSPECTION: Re-Inspection

RE-INSPECTION FEE DUE? ☑ **NO** ☐ **YES** **$ _____**

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS: justin.bennett **@co.kittitas.wa.us**

INSPECTION REQUEST LINE: 509-962-7694

http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506