KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER:	BP-15-00815	**OWNER'S NAME:**	RAGLAND
DATE:	3/7/2017	**TYPE:**	Plumbing
TIME STARTED:	2:41 PM	**INSPECTOR:**	Jeremy Haberman
MAP NUMBER:	18-17-05040-0007		

1. Plumbing Rough In OK. DWV at 5#/15min. OK. Supply at 60#/15min. OK.
2. Mechanical Rough In Not Complete.

INSTRUCTIONS: DO NOT COVER. Complete Mechanical Rough In.

NEXT INSPECTION: Mechanical

RE-INSPECTION FEE DUE? ☑ **NO** ☐ **YES** **$ _____**

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS: jeremy.haberman **@co.kittitas.wa.us**

INSPECTION REQUEST LINE: 509-962-7694

http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506