KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER:	BP-15-00891	**OWNER'S NAME:**	SIMMONS
DATE:	4/6/2017	**TYPE:**	Floor framing
TIME STARTED:	2:35 PM	**INSPECTOR:**	Justin Bennett
MAP NUMBER:	18-19-30059-0007		

1. Post and beam not installed per dwg
2. Blocking in progress

INSTRUCTIONS: Provide post and beam per dwg or engineer detail for joist support

NEXT INSPECTION: Re-Inspection

RE-INSPECTION FEE DUE? ☑ **NO** ☐ **YES** **$ _____**

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS: justin.bennett **@co.kittitas.wa.us**

INSPECTION REQUEST LINE: 509-962-7694

http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506