



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00942

OWNER'S NAME: ARIAS

DATE: 2/23/2016

TYPE: Post holes

TIME STARTED: 9:45 AM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 18-19-24057-0002

1. Holes Not Adequate Width. Minimum Hole Diameter is 18" x 18" Round or 12" x 12" Square.
2. Depth of Post Holes OK.
3. Crawl Space Access Must be Maintained. Relocate Crawl Access or Provide Hatch Through Completed Surface.

INSTRUCTIONS: Increase Diameter of Holes. Call for Reinspection. DO NOT POUR.

NEXT INSPECTION: Re Inspect Post Holes.

RE-INSPECTION FEE DUE? NO YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: _____ jeremy.haberman@co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506