



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00028

OWNER'S NAME: BOSS

DATE: 3/10/2016

TYPE: Frame-Plumb-Mech

TIME STARTED: 12:09 PM

INSPECTOR: Justin Bennett

MAP NUMBER: 17-19-06052-0001

1. DWV @ 5#/15 mins - Ok
2. Mechanical Ok
3. Framing @ Garage Ok
4. Wall Insulation Ok
5. NOTE: Windows are not vented per plans
6. NOTE: Windows are not tempered per plan
7. Post to beam installation (3) are not installed
8. Ok to cover Garage area

INSTRUCTIONS: Ok to cover/Verify vented & tempered windows @ next inspection

NEXT INSPECTION: Footings

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: _____ [justin.bennett @co.kittitas.wa.us](mailto:justin.bennett@co.kittitas.wa.us)

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506