



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00028

OWNER'S NAME: BOSS

DATE: 5/13/2016

TYPE: Plumbing

TIME STARTED: 9:30 AM

INSPECTOR: Justin Bennett

MAP NUMBER: 17-19-06052-0001

1. Framing corrections not observed - Verify next inspection
2. Sewage pump install Ok
3. Plumbing grade Ok
4. Studor vent installed on pump due to location for access

INSTRUCTIONS: Sewage pump installation Ok

NEXT INSPECTION: Final

RE-INSPECTION FEE DUE? NO YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: _____ justin.bennett@co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506