



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-16-00072

OWNER'S NAME: CHRISTIANSON

DATE: 3/9/2016

TYPE: Re-inspection

TIME STARTED: 9:59 AM

INSPECTOR: Justin Bennett

MAP NUMBER: 17-18-04052-0001

1. Gas line still @ 9# - Needs to be @ 15#/15 mins
2. Re-Fee
3. NOTE: Check gas line for leaks

INSTRUCTIONS: Re-Fee/Pressurize gas line to 15#/s/Re-Inspection

NEXT INSPECTION: Re-Inspection

RE-INSPECTION FEE DUE?

NO

YES

\$ 86.00

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  
ADDRESS: justin.bennett @co.kittitas.wa.us

**INSPECTION REQUEST LINE: 509-962-7694**

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506