



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00102

OWNER'S NAME: WULF

DATE: 6/28/2016

TYPE: Slab insulation

TIME STARTED: 9:54 AM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 21-16-31053-0002

1. Slab Insulation OK.
2. Thermal Break OK.
3. FRAMING CANNOT BE INSPECTED UNTIL PLUMBING/MECHANICAL/ELECTRICAL INSPECTIONS ARE COMPLETE.
4. Preliminary Framing Corrections Required.
5. Attic Accesses Not Complete. Attic Venting Not Acheived.
6. Wood Stove Rough In Not Complete.

INSTRUCTIONS: OK to Pour Bathroom Floor.

NEXT INSPECTION: Plumb/Mech

RE-INSPECTION FEE DUE? NO YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: jeremy.haberman @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506