



KITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-16-00102

OWNER'S NAME: WULF

DATE: 12/5/2016

TYPE: Mechanical

TIME STARTED: 12:56 PM

INSPECTOR: Justin Bennett

MAP NUMBER: 21-16-31053-0002

1. NOTE: Inspection intended for wood burning fireplace
2. Fireplace is installed with reduced clearances - need chimney data to verify
3. Fireplace does not have combustion air installed per Note D in permit fee sheet

**INSTRUCTIONS:** Install combustion air per note D/Provide chimney product data

**NEXT INSPECTION:** Re-Inspection

**RE-INSPECTION FEE DUE?**  NO  YES \$ \_\_\_\_\_

***IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION***

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  
ADDRESS: \_\_\_\_\_ [justin.bennett@co.kittitas.wa.us](mailto:justin.bennett@co.kittitas.wa.us)

**INSPECTION REQUEST LINE: 509-962-7694**

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506