



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-16-00108

OWNER'S NAME: GIGSTEAD

DATE: 6/15/2016

TYPE: Final

TIME STARTED: 9:14 AM

INSPECTOR: Jessica Contratto

MAP NUMBER: 18-19-32061-0001

1. Unable to locate stamped truss sheets
2. Gable bracing from post to truss top chord missing per plan page S2 (4 places )
3. Front gable end is a SW-2 shearwall. Inside is only halfway sheathed at these panels. See page S4 and note 8 page S0
4. Other framing and truss connections ok

**INSTRUCTIONS:** Complete above or obtain engineer approval for omittance

**NEXT INSPECTION:** re-inspect

**RE-INSPECTION FEE DUE?**  NO  YES \$ \_\_\_\_\_

***IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION***

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  
ADDRESS: \_\_\_\_\_ [jessica.contratto @co.kittitas.wa.us](mailto:jessica.contratto@co.kittitas.wa.us)

**INSPECTION REQUEST LINE: 509-962-7694**

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506