KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER:	BP-16-00137	**OWNER'S NAME:**	DAKOTA HEIGHTS
DATE:	5/9/2016	**TYPE:**	Foundation walls
TIME STARTED:	11:20 AM	**INSPECTOR:**	Justin Bennett
MAP NUMBER:	19-16-06052-0007		

1. Foundation walls with crawl require vertical #4 every 18" per 7/S2.0
2. Foundation walls with crawl max height 4'-0" per 7/S2.0
3. Provide engineering for current rebar installation
4. Do not pour foundation walls

INSTRUCTIONS: Do not pour/Provide engineering for current rebar configuration/Re-Inspection

NEXT INSPECTION: Re-Inspection

RE-INSPECTION FEE DUE? ☑ **NO** ☐ **YES** **$** _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS: justin.bennett **@co.kittitas.wa.us**

INSPECTION REQUEST LINE: 509-962-7694

http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506