KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER:	BP-16-00138	**OWNER'S NAME:**	DAKOTA HEIGHTS
DATE:	5/9/2016	**TYPE:**	Foundation walls
TIME STARTED:	11:39 AM	**INSPECTOR:**	Justin Bennett
MAP NUMBER:	19-16-06052-0001		

1. Foundation walls with crawl requires vertical #4 @ 18" OC per 9/S2.0
2. Do not pour
3. Provide engineer approval for current foundation wall installation

INSTRUCTIONS: Do not pour/Provide engineer approval for current installation/Re-Inspection

NEXT INSPECTION: Re-Inspection

RE-INSPECTION FEE DUE? ☑ **NO** ☐ **YES** **$ _____**

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:_____justin.bennett **@co.kittitas.wa.us**

INSPECTION REQUEST LINE: 509-962-7694

http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506