



KITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00172

OWNER'S NAME: SERTAV DEVELOPME

DATE: 9/7/2016

TYPE: Shearwalls

TIME STARTED: 1:45 PM

INSPECTOR: Jessica Contratto

MAP NUMBER: 20-15-19050-0088

1. Exterior shear ok
2. Strap by side entry door missing. Circled on plans. Have engineer address
3. Interior shaear ok

INSTRUCTIONS: Complete above, ok to cover

NEXT INSPECTION: Plumb/mech

RE-INSPECTION FEE DUE? NO YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: _____ [jessica.contratto @co.kittitas.wa.us](mailto:jessica.contratto@co.kittitas.wa.us)

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506