



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00172

OWNER'S NAME: SERTAV DEVELOPME

DATE: 11/15/2016

TYPE: Insulation

TIME STARTED: 12:19 PM

INSPECTOR: Justin Bennett

MAP NUMBER: 20-15-19050-0088

1. Exhaust Ok - Going to fur down ceiling in closet for exhaust
2. Corrections Ok
3. Insulation Ok
4. Install draft stop @ 2nd Flr @ attic

INSTRUCTIONS: DO NOT COVER FIREPLACE/Complete above/Re-Inspect draft stop

NEXT INSPECTION: Re-Inspection

RE-INSPECTION FEE DUE? NO YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: _____ [justin.bennett @co.kittitas.wa.us](mailto:justin.bennett@co.kittitas.wa.us)

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506