KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER:	BP-16-00187	**OWNER'S NAME:**	DK PROFESSIONAL
DATE:	5/4/2016	**TYPE:**	Mono pour
TIME STARTED:	12:05 PM	**INSPECTOR:**	Justin Bennett
MAP NUMBER:	20-14-12058-0023		

1. Setbacks by PUD/HOA
2. Add horizontal #4 bar @ rear of garage (maintain 12" OC)
3. Note: Added rebar installed while inspector present

INSTRUCTIONS: Ok to pour once above corrections are complete

NEXT INSPECTION: Exterior Shear

RE-INSPECTION FEE DUE? ☑ **NO** ☐ **YES** **$ _____**

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:_____justin.bennett **@co.kittitas.wa.us**

INSPECTION REQUEST LINE: 509-962-7694

http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506