



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00277

OWNER'S NAME: HEAD

DATE: 7/14/2016

TYPE: Slab insulation

TIME STARTED: 10:48 AM

INSPECTOR: Justin Bennett

MAP NUMBER: 20-15-19059-0009

1. Slab Insulation Ok
2. Ok to cover

INSTRUCTIONS: Ok to cover

NEXT INSPECTION: Exterior Shear

RE-INSPECTION FEE DUE? NO YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: _____ justin.bennett@co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506