



KITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00277

OWNER'S NAME: HEAD

DATE: 3/2/2017

TYPE: Multiple (see notes)

TIME STARTED: 11:36 AM

INSPECTOR: Justin Bennett

MAP NUMBER: 20-15-19059-0009

1. North (Master Bedroom) DWV @ 0# - Needs to be 15#
2. Supply @ 80#/15 mins - Ok
3. South DWV @ 5#/15 mins - Ok
4. Gas @ 18#/15 mins - Ok

INSTRUCTIONS: Pressurize North DWV

NEXT INSPECTION: Mechanical

RE-INSPECTION FEE DUE? NO YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: justin.bennett @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506