



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-16-00277

OWNER'S NAME: HEAD

DATE: 4/7/2017

TYPE: Mechanical

TIME STARTED: 11:14 AM

INSPECTOR: Justin Bennett

MAP NUMBER: 20-15-19059-0009

1. Complete heating and OA in downstairs
2. Install (2) LVL's @ stairs per A5
3. Tempered glass in Powder Room on A6 (Main Flr)
4. Provide Engineering for steel beam added in downstairs Bar/Bonus Rm
5. Provide LVL's @ downstairs stair header - (2) required
6. Provide Engineer letter for fireplace reinforcement
7. Trusses Ok
8. Exhaust Ok

**INSTRUCTIONS:** Complete above/Ok to insulate, do not cover any areas with outstanding corrections/Verify corrections @ insulation

**NEXT INSPECTION:** Insulation/Re-Inspection

**RE-INSPECTION FEE DUE?**  NO  YES \$ \_\_\_\_\_

***IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION***

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  
ADDRESS: \_\_\_\_\_ [justin.bennett @co.kittitas.wa.us](mailto:justin.bennett@co.kittitas.wa.us)

**INSPECTION REQUEST LINE: 509-962-7694**

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506