KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER:	BP-16-00283	**OWNER'S NAME:**	RIVERA
DATE:	10/5/2016	**TYPE:**	Framing
TIME STARTED:	10:42 AM	**INSPECTOR:**	Amber Green
MAP NUMBER:	18-17-12030-0014		

	1. Gasline (30#/15min) - OK
	2. DWV still not on test.
	3. Required truss bracing missing. Circled on truss sheets.
	4. Exhuast fans not complete.
	5. Bottom plate to sill nailing not per shearwall schedule at shearwall B in garage.
	6. Nail vertical 2x's to porch beams at wall entry per 3/SO.
	7. Re-check edge nailing at shearwall B in garage, to be 4" o.c.
	8. Woodstove clearance box installation OK. Will verify flue pipe termination with instal
	lation manual. Please provide at next inspection.

INSTRUCTIONS: Complete Above, Re-Call for Inspection. DO NOT COVER.

NEXT INSPECTION: Re-Inspection

RE-INSPECTION FEE DUE? ☑ **NO** ☐ **YES** **$** _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____amber.green **@co.kittitas.wa.us**